

水配管用亜鉛めっき鋼管 (SGPW) (JIS G 3442-1997抜粋)

Galvanized steel pipes for ordinary piping

亜鉛めっきを行う前の管の寸法、寸法許容差及び質量

管の呼び方		外径 mm	外径の許容差 mm	厚さ mm	厚さの許容差	ソケットを含まない 単位質量 kg/m
A	B					
10	3/8	17.3	±0.5	2.3	+規定しない -12.5%	0.851
15	1/2	21.7	±0.5	2.8		1.31
20	3/4	27.2	±0.5	2.8		1.68
25	1	34.0	±0.5	3.2		2.43
32	1 1/4	42.7	±0.5	3.5		3.38
40	1 1/2	48.6	±0.5	3.5		3.89
50	2	60.5	±0.5	3.8		5.31
65	2 1/2	76.3	±0.7	4.2		7.47
80	3	89.1	±0.8	4.2		8.79
90	3 1/2	101.6	±0.8	4.2		10.1
100	4	114.3	±0.8	4.5		12.2
125	5	139.8	±0.8	4.5		15.0
150	6	165.2	±0.8	5.0		19.8
200	8	216.3	±1.0	5.8		30.1
250	10	267.4	±1.3	6.6		42.4
300	12	318.5	±1.5	6.9		53.0